


Installing the Sensor


!WARNING!

Before performing service or maintenance operations on the systems, turn OFF main power switches to the unit. Electric shock can cause personal injury. Please read and follow the wiring instructions precisely; miswiring may cause permanent damage to the product.




Basic Installation for Non-Display Units

- 1. Separate the case into its front and rear sections.
- 2. Secure the rear section of the case to the wall or junction box using the supplied screws, and make necessary wire connections.
- **3.** Mount the Controller on the base by aligning the top clips and then securing to the bottom clips. Secure the Ventostat with the supplied set screw. A one-minute stabilization warmup will take place.




Amphenol Advanced Sensors



Basic Installation for Display Units

- 1. Separate the case into its front and rear sections.
- 2. Secure the rear section of the case to the wall or junction box using the supplied screws, and make necessary wire connections.
- **3.** Mount the Controller on the base by aligning the top clips and then securing to the bottom clips. Secure the Ventostat with the supplied set screw. A one-minute stabilization warmup will take place.
- **4.** When fitting the T8300 /T8400 (pitot tube version), complete the installation by screwing the tube connectors to the input ports on the sensor. The tubing connectors can be attached to either input port. It will not affect the performance of the sensor. (See page 3 for further instructions.)



Internal Label for Display Units

T63216-008 September 2014 Page 1 of 4

Ventostat Wiring Diagrams

The Ventostat family of products has two basic configurations. One configuration provides three active outputs (CO_2 , RH and temperature) and an independent thermistor. It has an output terminal block with pins #1, 2 and 3. The other configuration provides only CO_2 outputs and an independent thermistor and has no terminal block with pins 1, 2, and 3 installed. For electrical wiring and power supply requirements, these two configurations are identical; please follow the specific instructions for wiring. The recommended wire gauge is 18-22 AWG (1.0 to 0.75 metric).

!WARNING!


Ventostat products have three terminal pins that are connected inside the sensor to a common/ground: pin #2, 5 and 7 on the I/O terminal blocks and pin #2 on the power block. Do NOT connect positive (hot) 24 VAC power line to terminal number 2 of the terminal block.


Caution!

The T8100 Ventostats are either 3-wire or 4-wire type configurations, powered by either AC or DC voltage. They are not 2-wire or loop-powered devices. Wiring the units as 2-wire or loop-powered devices will irreparably damage the sensors and void the warranty.


Note: For temperature measurements, Ventostat models contain a passive thermistor (terminal pins #4 and 5), which is electrically isolated from the other circuitry and should be wired independently from active CO2/RH/temperature outputs. The thermistor has no connection to the Ventostat common ground and/or power.

The active temperature output has the same common (ground) as CO_2 and RH outputs.














Figure 4: Non-Display Unit Wiring for 4-Wire System, AC Power




Figure 5: Wiring CO₂ Sensor Voltage Output to Honeywell M7415 Damper Actuator with W7459 Logic Module

Sensing Duct CO₂ Concentrations


Duct-Mounting the Enclosures

Ventostat products can be installed inside the return air ductwork, if needed. As an alternative, please consider the T8031 unit. When mounting these products inside the ductwork, seal the hole around the wires and leave the duct insulation in place to prevent condensation which may damage the sensor.

Pitot Tube Installation for T8300/T8300-D and T8400/T8400-D

Install the mounting bracket, then install the pitot tube assembly as follows:

Note: The length of the Tygon® tubing is 6 ft. (1.8 m) with the optional T62892 pitot kit for the T8300. In order to maintain optimum accuracy, the tubing should not be lengthened. If the sensor is mounted closer than 3 ft. (0.9 m) the excess tubing should be shortened to avoid interference with mechanical or moving devices.



- 1. To mount the pitot tube, drill one 7/8" hole through the duct.
- Insert the pitot tube and mark the two remaining holes for the 2. mounting screws.
- 3. Punch or drill the two marked holes.
- Note the direction of airflow in the duct. 4.
- 5. Note the marking on the pitot tube flange and insert so that it is properly aligned with the airflow.
- To ensure an air tight seal, make sure the mounting surface of the 6. duct is clear of dirt or obstructions. Then, attach the pitot tube to the duct with sheet metal screws or rivets.
- 7. Check the length of the tubing before attaching to the sensor. The tubing should connect without stretching or pulling. If the length is long enough to create a loop or bind in the tubing, it should be shortened.
- 8. To shorten the tubing, remove the connectors that attach to the sensor and cut the tubing to length.
- Replace the tubing connectors by using a twisting or screwing 9. motion. Verify the connection is secure.
- Note: *If the tubing length has been shortened, be sure the in-line filter* is replaced on the pitot tube connector marked with an "H".

Accessory Enclosures

Model T1508 Duct Mount Enclosure (Aspiration Box)


The T8100/T8200/T8300 units can be installed inside a Model 1508 Duct Mount Enclosure.

Model T1552 Outside Air Measurement Enclosure

This NEMA-3R weatherproof enclosure includes thermostat and allows installing the sensor in environments with temperatures down to -40°F.

Model T1505 Harsh Environment Enclosure

For extreme environments where the sensor might be subjected to condensation or water spray such as those found in greenhouses or breweries- NEMA-3R rated.



Ventostat Specifications

Sensing Method

Non-dispersive infrared (NDIR) absorption Gold-plated optics Patented ABC Logic self calibration algorithm

CO₂ Measurement Range

T8100/T8200/T8300/T8400 0 to 2000 ppm (0 ppm = 0 V, 4 mA; 2000 ppm = 10/5V, 20 mA)

T8100/T8200/T8300/T8400 - 5P models 0 to 5000 ppm (0 ppm = 0 V, 4 mA; 5000 ppm = 10/5V, 20 mA)

CO₂ Accuracy

T8100/T8300 - Single Channel 400-1250 ppm ±30 ppm or 3% of reading, whichever is greater*,** 1250-5000 ppm ±5% of reading + 30ppm *, ** T8200/T8400 - Dual Channel 75 ppm or 10% of reading (whichever is greater)

- *Tolerance based on span gas of $\pm 2\%$
- ** ABC Logic not deactivated

Power Supply Requirements

18-30 VAC RMS, 50/60 Hz, or 18 to 42 VDC, polarity protected

*CO2 accuracy statement excludes standard gas used for calibration that has an accuracy of 2%. In addition, there is a potential digital to analog error of up to 1%.

Power Consumption

Typical 0.7 W at nominal voltage of 24V AC RMS

Temperature Dependence

0.2% FS per °C (±0.11% per °F)

Stability

T8100/T8300 - Single Channel <2% of FS over life of sensor (15 years)

T8200 - Dual Channel <5% of FS or <10% reading annual over life of sensor (10 years)

Pressure Dependence

0.135% of reading per mm Hg

Certifications

CE and RoHS compliant

Signal Update

Every 5 seconds

CO₂ Warm-up Time

< 2 minutes (operational) 10 minutes (maximum accuracy)

Operating Conditions

32°F to 122°F (0°C to 50°C) 0 to 95% RH, non-condensing

Storage Conditions

-40°F to 158°F (-40°C to 70°C)

Flammability Classification UL94 5VA

Thermistor Type NTC 10 KΩ thermistor

Thermistor Accuracy ±1°C (15° to 35°C)

RH Sensing Element

Capacitive polymer sensor

RH Range

0% to 99% RH (non-condensing)

RH Accuracy (25°C)

±2.5% RH (20 to 80% RH) ±3.5% RH (<20% and >80% RH)

Active Temperature Accuracy

±0.8°C @ 22°C

Active Temperature Range

0 to 50°C

ABC Logic[™] Self Calibration System

ABC LogicTM (Automatic Background Calibration) self calibration allows the sensor to continually recalibrate itself when the indoor concentrations drop to outside levels while the building is unoccupied. Generally a building must be regularly unoccupied for 4 hours or more for this self-calibration system to operate properly. Under these conditions, ABC LogicTM should maintain sensor calibration over the lifetime of the sensor. The ABC LogicTM should be turned OFF where a building is continuously occupied 24 hours per day, or where there could be significant sources of non-occupant related CO₂ such as greenhouses, breweries and other industrial and food processing applications.

Output

Analog 0 to 5 V, (100 Ω output impedance) 0 to 10 V (100 Ω output impedance) and 4 to 20mA (R_L maximum 500 Ω) available simultaneously for CO₂ output Digital to analog error ±1%

Warranty/Other

Warranty

18 months parts and labor

This product is covered by one or more of the following patents: 5,650,624 / 5,721,430 / 5,444,249 / 5,747,808 / 5,834,777 / 5,163,332 / 5,340,986 / 5,502,308 / 6,344,798 / 6,023,069 / 5,370,114 / 5,601,079 / 5,691,704 / 5,767,776 / 5,966,077 / 6,107,925 / 5,798,700 / 5,945,924 / 5,592,147 / 6,255,653 / 6,250,133 / 6,285,290

Warranty Repairs

Amphenol Thermometrics, Inc. will repair Telaire product that fails to meet the terms provided for in the Return and Warranty Policy Statement (See,_http://www.ge-mcs.com/en/services-andsupport.html).Warranty period shall start from date of manufacture and be based on product category and type of equipment as specified in Table 1: Product Warranty Periods. For all warranty repairs, Amphenol Thermometrics, Inc. will bear all product repair parts, labor, and standard ground shipping charges.

Customer Support Centers

U.S.A.

Sales and Services (Repair/Calibration):

Amphenol Thermometrics, Inc. St Marys Center 967 Windfall Road St Marys, Pennsylvania 15857 U.S.A. T: +1 814-834-9140 F: +1 814-781-7969

U.K.

Sales and Service:

Amphenol Thermometrics (U.K.) Limited Crown Industrial Estate Priorswood Road Taunton, TA2 8QY, UK T: +44 1823-335-200

Brazil

Sales and Service

Amphenol TFC DO Brazil LTDA Rodovia Governador Adhemar Pereira de Barros KM 121,5 S/N 13098-396 Campinas Sao Paulo, Brazil

U.S.A.

Technical Support: Amphenol Thermometrics, Inc. St Marys Center 967 Windfall Road St Marys, Pennsylvania 15857 U.S.A. T: +1 814-834-9140 F: +1 814-781-7969

Or

Amphenol Advanced Sensors 6860 Cortona Dr., Suite B Goleta, CA 93117, U.S.A.

China:

Amphenol (Changzhou) Connector Systems 305 Room, 5D Jintong Industrial Park Wujin, Changzhou, Jiangsu, China T:+86 519 8831 8080 ext. 50087 F:+86 519 8831 2601

Amphenol Advanced Sensors

www.amphenol-sensors.com

www.telaire.com

©2014 Amphenol Thermometrics, Inc. All rights reserved. Technical content subject to change without notice.